June 13, 2013

DELAWARE CITY 2012 WATER QUALITY REPORT

407 Clinton Street, Delaware City, DE 19706 PWSID: DE0000566 Report Created: May 2013

We are pleased to provide you with this annual water quality report for 2012. You will see that substances such as iron, chloride, and sodium are commonly found in drinking water. They occur naturally and, at trace levels, are not harmful to drink. The report shows at what levels any substances were found during tests conducted from January 1, 2012 - December 31, 2012, unless otherwise specified. If you have any questions about this report or the quality of your water, please contact Mr. Dick Cathcart, City Manager, at (302) 834-4573. If you wish to learn more, please attend any of the regularly scheduled meetings of Mayor and Council held the third Monday of each month at 6:30 p.m. in the Paul H. Morrill, Jr. Community Center, located at 250 Fifth Street, Delaware City, DE 19706.

A Safe Water Source

The water serving your home comes from the Potomac aquifer via two (2) wells at depths of 720 and 737 feet. This aquifer is confined and protected from the influence of past farming activities and saltwater intrusion. The Division of Public Health (DPH) in conjunction with the Department of Natural Resources and Environmental Control (DNREC) has conducted source water assessments for nearly all community water systems in the state. Copies can be obtained by contacting Mr. Dick Cathcart at (302) 834-4573 or by visiting DNREC's Source Water Program website at http://www.wr.udel.edu/swaphome/swassessments.html.

Expected Substances In Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:


- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and

City of Delaware City 407 Clinton Street P. O. Box 4159 Delaware City, DE



PRST STD U.S. POSTAGE PAID NEWARK, DE PERMIT NO. 20



BOXHOLDER DELAWARE CITY, DE 19706

Important information pertaining to Radon:

Radon is a radioactive gas that is found in nearly all soils. It typically moves up through the ground to the air and into homes through the foundation. Drinking water from a ground water source can also add radon to the home air. The EPA indicates that, compared to radon entering the home through soil, radon entering the home through water will in most cases be a small source of risk. The EPA and the State of Delaware have not yet set standards for monitoring radon in drinking water, although we do expect sampling to become mandatory in the near future. We are keeping a close eye on the situation and will be sure to comply with any new regulations as required.

Important Information Pertaining To Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead ex-

posure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have you water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe

Drinking Water Hotline (1-800-426-4791) or at www.epa.gov/safewater/lead.

If You Have A Special Health Concern

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Definition of Terms

In the table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

- 90th Percentile The ninth highest (out of a total of ten) lead and copper readings, used to determine compliance with the Lead and Copper Rule.
- Action Level The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL) the highest level of a contaminant that is allowed in drinking
 water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Disinfection Residual Level (MRDL) the highest level of a disinfectant in drinking water.
 There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- Maximum Disinfection Residual Level Goal (MRDLG) the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Nephelometric Turbidity Unit (NTU)** a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- Non-Detects (nd) laboratory analysis indicates that the constituent is not present.
- Not Regulated (n/r) no MCL identified because this substance is unregulated.
- Picocuries per Liter (pCi/l) a measure of the radioactivity in water.
- Parts per Billion (ppb) one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000.
- Parts per Million (ppm) one part per million corresponds to one minute in two years or a single penny in \$10,000.

								_
SUBSTANCES DETECTED	Violotion	_	Highest Level	(
Parameter	Yes / No	Unit of Measure	Allowed (MCL)	ideal Goal (MCLG)	Hignest Level Detected	Annual	Major Sources	
Inorganic Contaminants								
Fluoride	z	mdd	2	2	6.0	0.515 - 0.9	Water additive that promotes strong teeth.	
Barium (2010 Data)	z	qdd	2000	2000	27	23.8 – 27	Erosion of natural deposits.	11
Chromium (2010 Data)	zz	qd l	2 5	<u>6</u> ÷	2.9	2.6 – 2.9	Erosion of natural deposits.	
Nurate - nurite	2 2	E Ed	22,	26,	. e	0.3	Erosion of natural deposits.	
Nitrite	22	mud mud			170	0.70	Frosion of natural deposits.	
Radiological Contaminants								_
Radium, combined (2010 Data)	z	5	ın Y	00	0.67	0.31 - 0.67	Erosion of natural deposits.	_
Gross alpha excluding radon & uranium (2009 Data)	z	boa	2	5	0000	00.0	Elegion of Basic an opposite.	
					N			
Disinfection/Disinfection By-product Contaminants								_
Chlorine, Free Residual	z	mdd	4	4 4 6 I G	2.8	0.0 - 2.8	Disinfectant used in drinking water industry.	
Laboration Acide Pare	2	400	(MINUL)	(MINDEG)	80	0.0 – 5.8	Bv-product of drinking water chlorination.	
Dibromoacetic Acid		2 6	3 =	,	1.5	0.0 - 1.5		
Dichloroacetic Acid		qdd	n/r		6:1	0.0 1.9		
Monochloroacetic Acid		qdd	n/r		4.	nd – 1.4		
Trichloroacetic Acid		qd.	<u> </u>	,	6, 6	0.0 – 1.9	Control of spirit sections and section of the secti	
Trihalomethanes, total		add i	₽ 1	>	9.83 4.83	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	by-product of drinking water callornianoli.	
Bromodichiornemane		9 6	<u> </u>		2 0	80-00		
Chloriform	ZZ	od o	<u></u>		2.6	0.6 – 2.6	0	
Dibromochloromethane		qdd	1/4		3.8	0.0 - 3.8		Ÿ
Unregulated Contaminants	;		1		S	8		_
Alkatinity, Total الماريخيات	z 2	E de		250	16.9	6.91		_
Chlonde	2 2	E 66	- J	3	9.4	92-94		_
naroness, rotal (2011 Data)	2 2	i di	-	300	450	20 - 450		
(FC)	: z	0-14	1/1	7.5	8.2	6.8 - 8.2		_
Sodium	: z	mdd	n/r	20	46	46		_
Solids. Total Dissolved (2011 Data)	z	шdd	n/r	200	150	124 - 150		_
Sulfate	z	mdd	n/r	250	12.7	12.7		
					Offi Doesoontiis			M
Lead & Copper			Action Level		SO PERCONDE	0	Oseracion of harmonical alumbina auctoma	Т
90th Percentile Lead (2010 Data)	2	odd	2	5	C.1	ria - 3	Corresion of neuseriold plumbing systems,	
Number of Sites Exceeding Lead Action Level					0		Erosion of natural deposits	_
90th Percentile Copper (2010 Data)				0	0.567	0.05 - 0.64	Corrosion of household plumbing systems,	_
	z	mdd	1.3				Erosion of natural deposits	
Number of Sites Exceeding Copper Action Level		-			0			
			-					